

## Services

## Water - South

### Existing


- South part-Pressure District-5
- Ample water supply
- Good existing distribution system

### Proposed

- New watermain on all future roads

### Legend

- Proposed watermain 200mmØ
- Existing 150mmØ watermain
- Existing 200mmØ watermain
- Existing 300mmØ watermain
- Potential re-development properties





## Water - North



### Existing

- North part-pressure District-6
- Ample water supply
- Good distribution system

### Proposed

- (None)

### Legend

-  Existing 150mmØ watermain
-  Existing 200mmØ watermain
-  Existing 300mmØ watermain
-  Potential re-development properties





## Wastewater - South






### Existing


- Adequate York-Durham trunk capacity
- Borderline local capacity

### Proposed

- New parallel sewer or upgraded sewer may be needed on Hilda Avenue
- New collector sewer on future east-west road needed
- New local road sewers

### Legend

-  Proposed sanitary sewer
-  City sanitary sewer
-  Region of York sanitary trunk sewer
-  Sewer discharge
-  Potential Re-development properties





## Wastewater - North






### Existing

- Adequate York-Durham trunk capacity
- Adequate local capacity

### Proposed

- (None)

### Legend

-  Proposed sanitary sewer
-  City sanitary sewer
-  Region of York sanitary trunk sewer
-  Sewer discharge
-  Potential Re-development properties





## Stormwater Management - South

### Existing


- No known problems
- High sewer capacity
- Little or no Storm Water Management (SWM)

### Proposed

- SWM as per current Toronto and Region Conservation Authority requirements for all new development (on site)
  - Reduced run off volumes
  - Water quality improvements
- New sewers on Future Roads
- SWM for Future Roads

### Legend

- Future Storm Sewer
- York Region Storm Sewer
- City Storm Sewer
- Potential Re-development properties





## Stormwater Management - North

### Existing

- No known problems
- High sewer capacity
- Little or no Storm Water Management (SWM)

### Proposed

- SWM as per current Toronto and Region Conservation Authority requirements for all new development (on site)
  - Reduced run off volumes
  - Water quality improvements

### Legend

- Future Storm Sewer
- York Region Storm Sewer
- City Storm Sewer
- Potential Re-development properties

